



Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · www.gpwaterlab.com · ORELAP# OR100033

Mail To:

Grants Pass School District

Attn: District Office
725 NE Dean Dr.
Grants Pass, OR 97526

Date: May 14, 2019
Address of Source: 1725 Highland
Sample ID #: 21901637
Project Name: North Middle School

Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Doree Schaafsma
Laboratory Director

Sample Information

Sample ID: 21901637	Collectors Name: James Lowe
Address of Source: 1725 Highland	Sample Point: N/A
Project Name: North Middle School	Source: N/A
Received Date: 05/13/2019	Treatment System: None

Results of Chemical Analysis

Sample Notes:	Collection Date:	Fixture ID:							
B1 (42) West side wall student station	05/13/19 6:17 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AB	
B2 (47) West side wall student station	05/13/19 6:22 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AC	
B2 (49) West side wall student station	05/13/19 6:22 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AD	
B3 (51) East side wall student station	05/13/19 6:28 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AE	
B3 (52) East side wall student station	05/13/19 6:33 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AF	
B4 (61) South back wall student station	05/13/19 6:41 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AH	
B9 (76) Sink North Middle	05/13/19 6:46 AM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AI	
C1 (91) Classroom	05/13/19 6:55 AM	B DF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AJ	
C2 (93) Classroom	05/13/19 6:59 AM	B DF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AK	
C3 (95) Classroom	05/13/19 7:05 AM	B DF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AL	
Boys Locker Room (18) IM	05/13/19 7:17 AM	B ICE							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AA	
B3 (56) West side wall student station	05/13/19 6:40 PM	B CF							
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	05/14/19 8:18 am	JNS	AG	

DEFINITIONS AND DATA FLAGS

- A Analysis is covered under ORELAP scope of Accreditation
- AA Analysis is covered under ISO scope of Accreditation
- C Sample did not meet acceptance criteria
- H Analysis performed outside method hold time
- ID Subsample identifier for each Sample number
- M Matrix Spike recovery is out of control limits due to matrix interference
The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

- E Estimated Value
- LOQ Reporting Limit
- N/A Not Applicable
- ND None Detected
- S Sample Outsourced

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss